

---

# Inspection Summary

---

Permit #: PRCOM20182771, Building Permit - Commercial  
MAR BUILDING SOLUTIONS  
Address: 1445 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
Occupancy Inspection - Field Services	Marquelle Williams	Failed	Monday, October 14, 2019

Corrective Action Required

1 We are currently waiting on the As-Graded Dentention Basin that has to be changed and re-platted to be reviewed by the Development Engineers. A field inspection was done this morning and it appears that it is graded correctly and all the right size pipe and rip-rip has been installed properly. After this has been reviewed and approved by the engineers Development can issue a Substantial Completion.

Occupancy Inspection - Fire	Michael Weissenbach	Temporary C of O	Monday, October 14, 2019
-----------------------------	---------------------	------------------	--------------------------

Occupancy Inspection - Water Utilities	Curtis Deason	Passed	Monday, October 14, 2019
--	---------------	--------	--------------------------

**Comments:**

---