

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191098  
Address: 4060 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, October 15, 2019

Corrective Action Required:

1	Misc	-Use proper rebar grounding clamp listed for aluminum conductor -Bond service enclosure -Install #4 cu bonding jumpers from grounded bus bar to grounding bus bars where the GECs are connected to
---	------	--

**Comments:**