

PLANS REVIEW CONDITIONS

Permit No: PRCOM20173051 Date: October 16, 2019
Project Title: LEE'S SUMMIT MEDICAL CENTER - HCA Applicant:
MEDICAL OFFICE BUILDING
Location: JAYHAWK FIRE SPRINKLER CO INC
1980 SE BLUE PKWY, LEES SUMMIT, MO 64063 12030 S HEDGE LANE TERRACE
Type of Work: OLATHE, KS 66061
Occupancy Group: UC Primary: (913) 422-3770
Description: 3 STORY SHELL BUILDING FOR
FUTURE MEDICAL TENANTS
Construction Type: Type IIB (Unprotected)
Map Page: 196K

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test and a flow test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.