

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190941
Address: 4520 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Failed	Wednesday, October 16, 2019

Corrective Action Required:

1	Misc	** Need final ground stabilization ** All water is to be discharge 3' from foundation ** Seal exterior lights ** Switch and outlet covers are missing ** Bottom side of stairs where there could be storage needs to have drywall installed
---	------	---

Comments: