

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191610  
Address: 1507 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:  | Outcome: | Date:                       |
|-------------------------------------------|-------------|----------|-----------------------------|
| <b>All Rough Inspection - Residential</b> | Steve Quaid | Failed   | Wednesday, October 16, 2019 |

Corrective Action Required:

|   |      |                                                                                                                                                                                                                                                            |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | ** Need safety glass at stairway landing<br>** Loose braced wall panel on west wall<br>** Missing and loose foundation bolts in garage and basement<br>** Missing ledger lags on rear porch<br>** Verify porch header span. It appears to be over spanned. |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**