

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191541  
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Wednesday, October 16, 2019

Corrective Action Required:

1	Misc	IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. <b><u>PAINT 100% OF STEEL PIPE INCLUDING AT SUPPORTS.</u></b> SEE GAS PIPING AT METER AND REAR WALL.
---	------	--

Corrective Action Required:

2	Misc	SEAL GAS PIPE PENETRATION OF EXTERIOR WALL.
---	------	---

**Comments:**