

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190134  
Address: 1920 NE CATALINA AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Thursday, October 17, 2019

Corrective Action Required:

1	Misc	-Sidewalk not approved on record -Submit as-graded plot plan to city -Lawn irrigation permit -Water meter lid must flush with grade level -Provide min 6" clearance from window trim to grade -No pendant allowed in master closet
---	------	---

**Comments:**