

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191371
Address: 205 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Thursday, October 17, 2019

Corrective Action Required:

1	Misc	Pre-final inspection- 205 se Melody In 4. Install Vertical grab bars for bathrooms, rear grab bar. 9. Blow off pipe for water heater needs to extend to ground on exterior of building. INCORRECT PIPE USED. 10. Install auxiliary pan under water heater. PIPE DOWN TO FLOOR 17. Provide approved POS height counter top for sales. Center counter is over maximum height. see ANSI A117 or contact the architect. counter installed is over 36" -additional counter does not meet code.
---	------	--

Comments: