CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191809
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Partial	Friday, October 18, 2019

Partial Correction:

1	Misc	-COMPLETE PLUMBING TO NORTH SINK -HAVE ENGINEER RESUBMIT CHANGE OF THE GREASE WASTE BUILDING DRAIN FROM 6" TO 4"

Comments: