

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191807
Address: 1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mark Harding	Failed	Friday, October 18, 2019

Corrective Action Required:

1	Misc	south end of building This was a pre-final/ occupied building with out TCO with Codes and Fire Rough electrcial was inspected and panels, exterior panal needs re-inspected and grounnding size checked for 200 amp 3 phase. and where the old house panel is fed from . final will be when paint booth is submitted and complete. building is occupied.
---	------	---

Comments: