

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191192  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Partial	Friday, October 18, 2019

Corrective Action Required:	
1        Misc	BACKFLOW PROTECTION REQUIRED AT ALL EQUIPMENT PIPED WITH POTABLE WATER FOR CONSUMPTION.

Corrective Action Required:	
2        Misc	OBTAIN FIRE DEPARTMENT APPROVAL

Partial Correction:	
3        Misc	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. STAFFING, TRAINING, FIXTURING, STOCKING OK. NO PUBLIC/CUSTOMERS PRIOR TO APPROVAL.

**Comments:**