

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20191463  
Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Construction Inspection</b>	John Jackson	Partial	Saturday, October 19, 2019

Informational:

1 Misc

Tie-in of 6x8 Tee, 6" valve & and relocation of existing Fire Hydrant . The 90 degree "J" bend was replaced on the existing Fire Hydrant. All fitting have been mega lugged and contractor wrapped all installed DIP pipping with poly wrap. Contractor will fence off excavated area to pour thrust block behind 6"X8" Tee for Goddard School.

**Comments:**