

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192719
Address: 350 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line - Flush	Marquelle Williams	Passed	Monday, October 21, 2019

Informational:
1 Misc

OCTOBER 8, 2019

Inspector John DiMauro physically watched Advantage Fire flush the Fire Line for approx 1 hour.

Comments: