

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192719
Address: 350 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	Marquelle Williams	Partial	Monday, October 21, 2019

Informational:
1 Misc OCTOBER 3-4, 2019

At approx. 0+25.68, Fire Line is being installed. Piping has been replaced at both sides of pit. Piping is wrapped and bolts are sprayed. Sump Pumps have been added in pits.

Comments: