

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20192719  
Address: 350 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Fire Hydrant</b>	Marquelle Williams	Partial	Monday, October 21, 2019

Informational:  
1 Misc SEPTEMBER 30, 2019

Inspector arrived on site to inspect Fire Hydrant, 6" gate valve" and 90 degree Dip bends before Advantage Fire installed them.

Informational:  
2 Misc September 30, 2019

Inspector Inspected Fire Hydrant, Gate Valve, and Dip Bend after Advantage Fire installed them. Crews will be pouring thrust block restraints later on in the evening.

Informational:  
3 Misc OCTOBER 2, 2019

Inspector came out to Inspect Fire, Hydrant, Tees, Dip Bend, and Gate Valve. All items are installed correctly. @ STA. 1+36.59.

**Comments:**