

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191317
Address: 1712 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Monday, October 21, 2019

Corrective Action Required:

1	Misc	- front straps need to be uncovered from siding - secure gas line to fire place - clean up the curbs and street along Merryman Dr. fix all erosion control that is currently down
		Ok to insulate

Comments: