CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190638

Address: 4720 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Khanh Nguyen Failed Monday, October 21,

Residential 2019

Corrective Action Required:

1 Misc -COMPLETE INSTALLING STRAPS ON THE INTERIOR SIDES OF BOTH POST&KNEE

WALLS PER ENGINEER LETTER DATED OCTOBER 18

-COMPLETE REINFORCE THE OUTER SIDES OF BOTH POST&KNEE WALLS PER

ORIGINAL LETTER. INSTALL A SIMPSON LTP5 DEVICE

Comments: