

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision
MONTICELLO 3RD PLAT

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	Steve Robbins	Passed	Tuesday, October 22, 2019
DE - Erosion Sediment Control (ESC) Inspection	Steve Robbins	Failed	Tuesday, October 22, 2019

Corrective Action Required

- 1 A complaint from 4712 Pocono Circ was received about silt running to their yard from the houses behind. I checked the complaint and it appears that silt has ran down from lot 4705, 4709, and 4713 and has filled in the swale that runs between the houses. The houses have silt fence up as of now but it appears that it has failed recently as there is a lot of silt in the swale and has come over in the yard of 4712 Pocono circ. I will reach out to the developer to see if he can work together with the builders to get this taken care of.

Comments: