

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20192368
Address: 713 SW 15TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Vacuum	Marquelle Williams	Failed	Tuesday, October 22, 2019

Informational:
1 Misc OCTOBER 15, 2019

Manhole A4=PASSED
Manhole A3=PASSED
Manhole A2 FAILED

Comments: