



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20191957	Date:	October 22, 2019
Project Title:	HEALTHY LOOKS MEDSPA	Applicant:	
Location:			
930 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086		ABSOLUTE FIRE INC	
Type of Work:		13906 CENTURY LN	
Occupancy Group:	B	GRANDVIEW, MO 64030	
Description:	TENANT FINISH FOR MEDSPA		
Construction Type:	Type IIB (Unprotected)	Primary:	(816) 737-9991
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. (Action Required)

Current annual inspection tag posted on the riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.