CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20181650Address:2525 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Tuesday, October 22, 2019

Corrective Action Required:

1	Misc	 Seal outside light fixtures and outside penetrations through the siding
		 Second locking device needed for back sliding door
		-gfci in garage is not working properly
		 water meter pit needs to be brought down to grade level
		- Splash blocks need to be put out
		 sump pump discharge needs to be 36" from foundation wall
		- window screens need to be Installed
		 outside gfci by AC unit not working properly

Comments: