



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20192581	Date:	October 22, 2019
Project Title:	SAINT LUKE'S EAST HOSPITAL I.R & X-RAY EQUIPMENT REPLACEMENT	Applicant:	
Location:		AMERICAN FIRE SPRINKLER CORPORATION	
	80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086	PO BOX 958	
Type of Work:		MISSION , KS 66201	
Occupancy Group:	I-2	Primary: (913) 722-6900	
Description:	EQUIPMENT REPLACEMENT FOR SAINT LUKES HOSPITAL		
Construction Type:	Not Applicable		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. (Action Required)
Current annual inspection tag posted on riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.