

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, October 23, 2019

Partial Correction:

1	Misc	CORRIDOR CROSSWALL AT DOOR #103 OK TO COVER: FRAMING; 1ST LAYER 5/8" TYPE X GWB; 2ND LAYER 5/8" TYPE X GWB
---	------	---

Comments: