

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192660
Address: 1533 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Brandon Kalwei	Failed	Wednesday, October 23, 2019

Corrective Action Required:

1	Misc	-No address posted -no rebar in place as plan shows Do not pour Call back in when ready
---	------	--

Comments: