

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192954
Address: 1704 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Wednesday, October 23, 2019

Corrective Action Required:

1	Misc	- Protect clean out stack at top and bottom plate, turn out clean out toward wall for access - Stud shoes needed for over bored studs in bathroom, or double up - fire block at top plate in bedroom closet west wall, to prevent going into firred or ceiling
---	------	--

Ok to insulate

Comments: