

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182343
Address: 1623 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Wednesday, October 23, 2019

Corrective Action Required:

1	Misc	- Secure waterline to foundation in unfurnished area if basement - must fire protect I joists in both unfinished areas of basement
---	------	---

Comments: