

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191809  
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Khanh Nguyen	Partial	Wednesday, October 23, 2019

Partial Correction:  
1 Misc -HAVE ENGINEER RESUBMIT CHANGE OF THE GREASE WASTE BUILDING DRAIN  
FROM 6" TO 4"

**Comments:**