# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20190638

Address: 4720 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Wednesday, October

Residential 23, 2019

### Corrective Action Required:

1 Misc -Reinforcement at the outer side of the hinge-joint not done per 1st engineer

letter. Straps on the interior side of the hinge joint are installed per revised

engineer letter and is OK.

-Re-inspection fee assessed on 7/12 not paid.

-Water meter well needs cleaned out of mud and debris.

-Provide proper slope away from the basement walk-up stem wall; install

downspout splash blocks

-Garage receptacle not tripping; or it must be single-plug dedicated receptacle

-Provide mean to clean out the furnace condensate drain

-Provide battery backup for the outdoor drain outlet sump pump

## **Comments:**