CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20184098Address:1518 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Wednesday, October 23, 2019

Corrective Action Required:

Misc	- Both locking devices needed for back sliding door on main and basement
	level
	 Gfci receptacle I'm back deck is not working properly
	- anti siphon devise needed for hose bib in basement
	 lockout devices needed for microwave and oven
	- detector for downstairs bedroom needs to be combo unit smoke and CO

- security strike plate or screws needed for door leading to downstairs garage
- gfci outside of lower level garage not working properly
- final grade, sod, splash blocks

- seal all outside electrical fixtures, ac disconnect, etc.

Comments:

1