

# Inspection Summary

Permit #: PRCOM20191541, Building Permit - Commercial  
MARTIN CITY PIZZA & TAPS  
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Steve Robbins	Passed	Thursday, October 24, 2019

Informational

- 1 A hydrostatic pressure test was done for 2 hr. on the new 6" fire line that was insalled and ran into the building.

Comments: