

Inspection Summary

Permit #: PRCOM20191541, Building Permit - Commercial
MARTIN CITY PIZZA & TAPS
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Steve Robbins	Passed	Thursday, October 24, 2019

Informational

1 A hydrostatic pressure test was done for 2 hr. on the new 6" fire line that was insalled and ran into the building.

Water Service Inspection - Commercial	Joe Starlin	Passed	Thursday, October 24, 2019
--	-------------	--------	----------------------------------

Informational

1 The new water meter has been installed and ran to the building and the existing water meter was removed and a repair clamp was installed on the main.

Comments: