

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191541
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|----------------------------|
| Occupancy Inspection - Codes Commercial | John Borns | Failed | Thursday, October 24, 2019 |

| | |
|-----------------------------|---|
| Corrective Action Required: | |
| 1 Misc | FACADE IMPROVEMENTS BY LANDLORD TO BE COMPLETED AND APPROVED BY DEVELOPMENT SERVICES. |
| Corrective Action Required: | |
| 2 Misc | OBTAIN FULL APPROVAL FROM: - LS FIRE DEPT - LS CIVIL INSPECTION (FINISH SITEWORK) |
| Corrective Action Required: | |
| 3 Misc | PROVIDE TECH DATA RE NON-ABSORBENT RESTROOM FLOORS |
| Corrective Action Required: | |
| 4 Misc | PROVIDE TECH DATA ON WINDOW FILM REGARDING HAZARDOUS GLASS LOCATIONS |
| Corrective Action Required: | |
| 5 Misc | PROVIDE TECH DATA RE BACKFLOW PREVENTION AT ICEMAKER |
| Corrective Action Required: | |
| 6 Misc | IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST: NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR BEFORE ANY PRODUCTION USE IS APPROVED. |
| Corrective Action Required: | |
| 7 Misc | LICENSE TAX IS DUE BEFORE OPENING FOR OPERATION |

Comments: