

Inspection Summary

Permit #: PRCOM20191541, Building Permit - Commercial
MARTIN CITY PIZZA & TAPS
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Thursday, October 24, 2019

Corrective Action Required

1 FACADE IMPROVEMENTS BY LANDLORD TO BE COMPLETED AND APPROVED BY DEVELOPMENT SERVICES.

Corrective Action Required

2 OBTAIN FULL APPROVAL FROM:
- LS FIRE DEPT
- LS CIVIL INSPECTION (FINISH SITEWORK)

Corrective Action Required

3 PROVIDE TECH DATA RE NON-ABSORBENT RESTROOM FLOORS

Corrective Action Required

4 PROVIDE TECH DATA ON WINDOW FILM REGARDING HAZARDOUS GLASS LOCATIONS

Corrective Action Required

5 PROVIDE TECH DATA RE BACKFLOW PREVENTION AT ICEMAKER

Corrective Action Required

6 IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST: NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR BEFORE ANY PRODUCTION USE IS APPROVED.

Corrective Action Required

7 LICENSE TAX IS DUE BEFORE OPENING FOR OPERATION

Occupancy Inspection - Water Utilities	Curtis Deason	Passed	Thursday, October 24,
--	---------------	--------	-----------------------

2019

Miscellaneous Inspection Steve Robbins Passed Thursday,
October 24,
2019

Informational

- 1 A hydrostatic pressure test was done for 2 hr. on the new 6" fire line that was insalled and ran into the building.

Water Service Inspection - Joe Starlin Passed Thursday,
Commercial October 24,
2019

Informational

- 1 The new water meter has been installed and ran to the building and the existing water meter was removed and a repair clamp was installed on the main.

Occupancy Inspection - Field Steve Robbins Temporary C of O Thursday,
Services October 24,
2019

Informational

- 1 Need to have sod or vegetation established, it was said they will probably sod in the next few weeks, so i will check back in a few weeks.

Comments:
