

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170407

Address: 3560 SW HOLLYWOOD DR, Unit:6, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Brandon Kalwei	Failed	Friday, October 25, 2019

Corrective Action Required:

1	Misc	-207 spindle spacing bent at porch -205 rock wool in hole 3x6" cover with Sheetrock. -Storage unit 6 fire caulk around 2" pipe -Gfci units 306-07 stacks counter A1 units -Gfci needed in safe room in basement -E3902.6 kitchen counter - Unit 306 gfci needed in kitchen, east wall - Unit 307 gfci needed in kitchen, west wall Smoke detector covered up in bedroom -unit 08 fire caulk waterlines going through ceiling in mechanical room - unit 06 gfci needed on east wall in kitchen
---	------	---

Comments: