

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20181907
Address: 249 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|--------------------------|
| Footing Inspection - Commercial | Mark Harding | Partial | Friday, October 25, 2019 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Lower exterior footing , ufer needs to be installed in upper footings |
|---|------|--|

Comments: