

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20190138  
Address: 2240 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Friday, October 25, 2019

Corrective Action Required:

1	Misc	In-wall from col. line 3 to 1: -Protect plumbing (DVW and water lines) where located within 1.25" of surface of stud/track. Shield plate shall extend min 2" above bottom wall track. -Secure water lines at mid-wall height -Complete P9 wall at manager office rm 108
---	------	--

Comments: