

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Friday, October 25, 2019

Partial Correction:

1 Misc

GAS PIPING SYSTEM HELD PRESSURE AT >10 PSI FOR >10 MIN.

IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. PAINT 100% OF STEEL PIPE INCLUDING AT SUPPORTS. SEE GAS PIPING AT BUILDING ENTRY AND ROOFTOP.

Comments: