

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183649
Address: 4505 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Monday, October 28, 2019

Corrective Action Required:

1	Misc	?Take covers off of smoke and CO detectors ?Outlet on west side counter in kitchen not working properly ?Verify that microwave is either plug in unit or hardwired, needs lockout devise it is ?Hand railing needed for deck ?Final grade, sod, splash blocks ?Seal outside light fixtures -Water meter well needs to have gravel removed
---	------	---

Comments: