CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192786 Address: 1006 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Above Ceiling Inspection		John Borns	Failed	Monday, October 28, 2019
Corrective	Action Required:			
1	Misc	SUPPORT WIRES AT LAY-IN ELECTRICAL LUMINAIRES: PROVIDE TWO SLACK WIRE TIES PER FIXTURE FROM STRUCTURE TO TWO OPPOSITE DIAGONAL CORNERS. TIE BOTH ENDS WITH TWO FULL WRAPS MINIMUM.		
Corrective	Action Required:			
2	Misc	LOW-VOLTAGE ELECTRICAL CABLE: - REMOVE ANY ABANDONED CABLE		
.		- STRAP ALL REMINING TO	HARD LID	
	Action Required:			
3	Misc	SUPPORT MC CABLE RUNS	TO HARD LID.	
Corrective	Action Required:			
4	Misc	NEC 110-12: PLUG ANY UN BOXES.	USED OPENINGS AT FIXTURE	S AND JUNCTION

Comments: