

# **Inspection Summary**

Permit #: PRPWFC20173611, Public Works Infrastructure Permit - Commercial Village at View High On-Site Infrastructure

Address: 3390 NW VILLAGE PARK DR, LEES SUMMIT, MO 640813391 NW VILLAGE PARK DR, LEES SUMMIT, MO 64081245 NW KESSLER DR, LEES SUMMIT, MO 64081201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Sewer Construction Inspection	Steve Robbins	Partial	Monday, October 28, 2019

#### Informational

- Blue Nile Construction was out today grouting in the curb inlets that were not finished last summer. They were hoping to finish all of them up today, if not they will finish on Monday. Informational
- The curb inlets have all been grouted and the storm line has been flushed but they still have some of the hooks to take off the storm box lids.

DE - Water Line - Construction Steve Robbins	Passed	Monday,	
Inspection		October 28,	
		2019	

### Corrective Action Required

The water samples passe last december for this water line but the new main on village park dr. was never connected to view high dr. and the construction taps were never removed. On friday 9/27 the main was chlorinated again so we will dechlorinate and take samples on line 2 of the water main going down village park dr.

#### Resolved

The water line has been re-tested and has recieved passing tests from Keystone Lab. The water line at View High and Village Park has been tied in and is in full service. The fire hydrants have all been turned toward the street and raised if they needed it. This now completes all the water for this permit.

DE - Water Line - Construction	Steve Robb	oins
Taps Removed		

Passed

Monday, October 28, 2019

					าล	

1 The construction taps have been removed and repalaced with repair clamps.

## **Comments:**