

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192709  
Address: 4516 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	Brandon Kalwei	Failed	Tuesday, October 29, 2019

Corrective Action Required:

1	Misc	-No address posted -Clean up street of dirt and debris, fix erosion control -Drain tile needs to be corrected and set
---	------	---

**Comments:**