

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190941
Address: 4520 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Tuesday, October 29, 2019

Corrective Action Required:

1	Misc	** Need final ground stabilization ** All water is to be discharge 3' from foundation ** final grade, sod, splash blocks needed
---	------	---

Comments: