

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192395  
Address: 910 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Tuesday, October 29, 2019

Corrective Action Required:

1	Misc	REMOVE TEMPORARY LIGHT FIXTURE AND HANGERS
---	------	--------------------------------------------

Corrective Action Required:

2	Misc	NEC 334-10 SECURING / SUPPORT OF MC ELECTRICAL CABLE: SECURE WITHIN 12" OF BOXES. USE CLAMPS THAT FASTEN MC IN PLACE WITHIN 12" OF BOX ENTRY.
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**