

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192007
Address: 1900 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Tuesday, October 29, 2019

Corrective Action Required:

1	Misc	-Fire block double walls in basement vertically - protect plumbing and waterlines in downstairs basement bathroom at top plate - protect piping at bottom plate in pantry -ok to insulate
---	------	--

Comments: