

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190138
Address: 2240 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Tuesday, October 29, 2019

Corrective Action Required:

1	Misc	In-wall from col. line 3 to 1: -Protect plumbing (DVW and water lines) where located within 1.25" of surface of stud/track. Shield plate shall extend min 2" above bottom wall track.
---	------	--

Comments: