

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190274

Address: 2861 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Tuesday, October 29, 2019

Corrective Action Required:

1	Misc	2-HR FIRE BARRIER WALL: -WALL FROM H.8/7 TO J.5/7-1ST LAYER OK -WALL IN ELECTRICAL RM-1ST LAYER OK
---	------	--

Comments: