

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191115
Address: 811 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|---------------------------|
| Electrical Service Inspection - Commercial | Khanh Nguyen | Passed | Tuesday, October 29, 2019 |

Comments:

THE 200 AMP UPGRADE IS OK. HOWEVER, THE 600 AMP MAIN SERVICE DISCONNECT GROUDING IS NOT IN COMPLIANCE