

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182609
Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Failed	Wednesday, October 30, 2019

Partial Correction:

1	Misc	OK TO GWB ONE-SIDE DOUBLE-WYTHE STAIRWELL WALLS:
		NORTH STAIR: BASEMENT LEVEL; 1ST FLOOR;
		SOUTH STAIR: 1ST FLOOR;
Corrective Action Required:		
2	Misc	STAIR NOT BUILT FOR ACCESS

Comments: