

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191770

Address: 2861 NE INDEPENDENCE AVE, Unit:101, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Wednesday, October 30, 2019

Partial Correction:

1 Misc

2-HR FIRE BARRIER:

-ELECTRICAL RM-2ND LAYER OK

-SPRINKLER RM-1ST LAYER OK

-WEST WALL COLUMNS-1ST LAYER

-WALL LINE 7 FROM H.8 TO J.5-2ND LAYER OK WITHIN SOFFIT, 1ST LAYER OK BELOW SOFFIT

Comments: