

SAB Construction
Solaia

Air Combustion Calculation			
Per IRC 2018 G2407.5.1			
Fuel Burning Appliance #1	Furnace	100000	Btu/h
Fuel Burning Appliance #2		50000	Btu/h
Fuel Burning Appliance #3		NA	Btu/h
Total Btu/h		150000	Btu/h
Area of useable space		596	sq.ft
Ceiling height in useable space (no sheetrock)		9	ft
Volumne of space		5364	
Required Volume of Air = total Btu/h * (50 cu.ft/1000 Btu/h)		7500	cu.ft.
Required Area of Usable Space		834	sq.ft.
Standard Method of Work?		BAD	
Combustion Air Transfer Grille			
Per IRC G2407.5.3.1			
Required Opening Free Space = 1 sq.in./1000 Btu/h			
	=	160	sq.in.
Size of grille to be used	=	(2) 14"x8"	
Note: If fuel burning appliances are enclosed, (1) opening is required within 12" of floor and (1) opening is required within 12" of top enclosure			

SAB Construction

RECEIVED
OCT 28 2019
Development Services